

Tennessee Storm Water Multi-Sector  
General Permit for Industrial Activities (TMSP)  
**Sector AE**

**EE     Sector AE - Storm Water Discharges Associated With Industrial Activity From Facilities That Are Not Covered Under Sectors A Thru AC (Monitoring Not Required)**

**1. Discharges Covered Under This Section**

The requirements listed under this section shall apply to storm water discharges associated with industrial activity from those facilities that are not covered for such discharges under Sectors A thru AC, but due to nature of manufacturing or industrial process at a site, do not require analytical monitoring of storm water runoff. It is the intent of the Division that this Sector include those storm water discharges which are not covered under Sectors A thru AC, as well as those facilities which had no previous storm water permit that are applying for the first time and will not be covered under Sectors A thru AC.

<b>SIC Code</b>	<b>Sector AE: Facilities That Are Not Covered Under Sectors A Thru AC (Monitoring Not Required)</b>	<b>Sampling Required?</b>	<b>Table Number</b>
N/A	Nonclassifiable Establishments	No	--

When an industrial facility, described by the above coverage provisions of this section, has industrial activities being conducted onsite that meet the description(s) of industrial activities in another section(s), that industrial facility shall comply with any and all applicable monitoring and pollution prevention plan requirements of the other section(s) in addition to all applicable requirements in this section. The monitoring and pollution prevention plan terms and conditions of this multi-sector permit are additive for industrial activities being conducted at the same industrial facility (co-located industrial activities). The operator of the facility shall determine which other monitoring and pollution prevention plan section(s) of this permit (if any) are applicable to the facility.

**2. Special Conditions**

Prohibition of Non-storm Water Discharges. Except for those allowable non-storm water discharges included in Part IIIA2 (Allowable Non-Storm Water Discharges) of this permit, there are no other non-storm water discharges authorized in this Sector.

**3. Storm Water Pollution Prevention Plan Requirements**

Contents of Plan. If the facility was previously permitted and subject to the TMSP's storm water pollution prevention plan requirements, the permittee may substitute it's current storm water pollution prevention plan for the one required below, provided it meets the minimum requirements of the following plan; otherwise, the plan shall include, at a minimum, the following items:

Pollution Prevention Team. Each plan shall identify a specific individual or individuals within the facility organization as members of a storm water Pollution Prevention Team that are responsible for developing the storm water pollution prevention plan and assisting the facility or plant manager in its implementation, maintenance, and revision. The plan shall clearly identify the responsibilities of each team member. The activities and responsibilities of the team shall address all aspects of the facility's storm water pollution prevention plan.

Description of Potential Pollutant Sources. Each plan shall provide a description of potential sources which may reasonably be expected to add significant amounts of pollutants to storm water

discharges or which may result in the discharge of pollutants during dry weather from separate storm sewers draining the facility. Each plan shall identify all industrial activities and significant materials which may potentially be significant pollutant sources. Each plan shall specifically identify the physical features of the facility that may contribute to storm water runoff. Each plan shall include, at a minimum:

**Drainage.** A site map indicating the outfall locations and types of discharges contained in the drainage areas of the outfalls, an outline of the portions of the drainage area of each storm water outfall that are within the facility boundaries, each existing structural control measure to reduce pollutants in storm water runoff, surface water bodies, locations where significant materials are exposed to precipitation, and locations where major spills or leaks identified under Part IX.AD.3.a.(2)(c) (Spills and Leaks) of this permit have occurred.

For each area of the facilities that generates storm water discharges associated with industrial activity with a reasonable potential for containing significant amounts of pollutants, a prediction of the direction of flow, and an identification of the types of pollutants which are likely to be present in storm water discharges associated with industrial activity. Factors to consider include the toxicity of chemical; quantity of chemicals used, produced or discharged; the likelihood of contact with storm water; and history of significant leaks or spills of toxic or hazardous pollutants. In addition, flows with a significant potential for causing erosion shall be identified such as heavy equipment use areas, drainage from roofs, parking lots, etc.

**Inventory of Exposed Materials—**An inventory of the types of materials handled at the site that potentially may be exposed to precipitation. Such inventory shall include a narrative description of significant materials that have been handled, treated, stored or disposed in a manner to allow exposure to storm water between the time of 3 years prior to the date of the submission of a Notice of Intent (NOI) to be covered under this permit and the present; method and location of onsite storage or disposal; materials management practices employed to minimize contact of materials with storm water runoff between the time of 3 years prior to the date of the submission of a Notice of Intent (NOI) to be covered under this permit and the present; the location and a description of existing structural and nonstructural control measures to reduce pollutants in storm water runoff; and a description of any treatment the storm water receives.

**Spills and Leaks—**A list of significant spills and significant leaks of toxic or hazardous pollutants that occurred at areas that are exposed to precipitation or that otherwise drain to a storm water conveyance at the facility after the date of 3 years prior to the date of the submission of a Notice of Intent (NOI) to be covered under this permit. Such list shall be updated as appropriate during the term of the permit.

**Sampling Data—**A summary of existing discharge sampling data describing pollutants in storm water discharges from the facility, including a summary of sampling data collected during the term of this permit.

**Risk Identification and Summary of Potential Pollutant Sources—**A narrative description of the potential pollutant sources from the following activities: loading and unloading operations, chemicals and raw materials; outdoor storage activities for raw materials; outdoor manufacturing or processing activities; significant dust or particulate generating processes; and onsite waste disposal practices. The description shall specifically list any significant potential source of pollutants at the site and for each

Tennessee Storm Water Multi-Sector  
General Permit for Industrial Activities (TMSP)  
**Sector AE**

potential source, any pollutant or pollutant parameter (e.g., biochemical or chemical oxygen demand, chromium, total suspended solids, oil and grease, etc.) of concern shall be identified.

**Measures and Controls.** Each facility covered by this permit shall develop a description of storm water management controls appropriate for the facility, and implement such controls. The appropriateness and priorities of controls in a plan shall reflect identified potential sources of pollutants at the facility. The description of storm water management controls shall address the following minimum components, including a schedule for implementing such controls:

**Good Housekeeping—**Good housekeeping requires the maintenance of areas which may contribute pollutants to storm water discharges in a clean, orderly manner.

**Preventive Maintenance—**Preventive maintenance measures shall include timely inspection and maintenance of storm water management devices (e.g., cleaning oil/water separators, catch basins) as well as inspecting and testing facility equipment and systems to uncover conditions that could cause breakdowns or failures resulting in discharges of pollutants to surface waters, and ensuring appropriate maintenance of such equipment and systems.

**Spill Prevention and Response Procedures—**Areas where potential spills which could contribute pollutants to storm water discharges may occur, and their accompanying drainage points shall be identified clearly in the storm water pollution prevention plan. Where appropriate, specifying material handling procedures, storage requirements, and use of equipment such as diversion valves in the plan should be considered. Procedures for cleaning up spills shall be identified in the plan and made available to the appropriate personnel. The necessary equipment to implement a clean up should be available to personnel.

**Inspections—**Qualified facility personnel shall be identified to inspect designated equipment and areas of the facility at appropriate intervals specified in the plan. A set of tracking or follow-up procedures shall be used to ensure that appropriate actions are taken in response to the inspections. Records of inspections shall be maintained.

**Employee Training—**Employee training programs shall inform personnel responsible for implementing activities identified in the storm water pollution prevention plan or otherwise responsible for storm water management at all levels of responsibility of the components and goals of the storm water pollution prevention plan. Training should address topics such as spill response, good housekeeping, and material management practices. The pollution prevention plan shall identify periodic dates for such training.

**Recordkeeping and Internal Reporting Procedures—**A description of incidents (such as spills, or other discharges), along with other information describing the quality and quantity of storm water discharges shall be included in the plan required under this part. Inspections and maintenance activities shall be documented and records of such activities shall be incorporated into the plan.

#### **Non-storm Water Discharges**

The plan shall include a certification that the discharge has been tested or evaluated for the presence of non-storm water discharges. The certification shall include the identification of potential significant sources of non-storm water at the site, a description of the results of any test and/or evaluation

for the presence of non-storm water discharges, the evaluation criteria or testing method used, the date of any testing and/or evaluation, and the onsite drainage points that were directly observed during the test. Certifications shall be signed in accordance with Part VII.G. of this permit. Such certification may not be feasible if the facility operating the storm water discharge associated with industrial activity does not have access to an outfall, manhole, or other point of access to the ultimate conduit which receives the discharge. In such cases, the source identification section of the storm water pollution prevention plan shall indicate why the certification required by this part was not feasible, along with the identification of potential significant sources of non-storm water at the site. A discharger that is unable to provide the certification required by this paragraph must notify the Division of Water Pollution Control in accordance with paragraph "Failure to Certify" (below).

Sources of non-storm water that are combined with storm water discharges associated with industrial activity must be identified in the plan. The plan shall identify and ensure the implementation of appropriate pollution prevention measures for the non-storm water component(s) of the discharge. Any non-storm water discharges that are not permitted under an individual NPDES permit should be brought to the attention of the Division's local Environmental Assistance Center (see list of EACs on page 15).

**Failure to Certify**—Any facility that is unable to provide the certification required (testing for non-storm water discharges), must notify the Division of Water Pollution Control by not later than 180 days after submitting a notice of intent to be covered by this permit. If the failure to certify is caused by the inability to perform adequate tests or evaluations, such notification shall describe: the procedure of any test conducted for the presence of non-storm water discharges; the results of such test or other relevant observations; potential sources of non-storm water discharges to the storm sewer; and why adequate tests for such storm sewers were not feasible. Non-storm water discharges to waters of the State which are not authorized by an NPDES permit are unlawful, and must be terminated.

**Sediment and Erosion Control**—The plan shall identify areas which, due to topography, activities, or other factors, have a high potential for significant soil erosion. The plan shall identify structural, vegetative, and/or stabilization measures to be used to limit erosion. These shall include but not be limited to grass swales, filter strips, treatment works, or other equivalent measures.

**Management of Runoff**—The plan shall contain a narrative consideration of the appropriateness of traditional storm water management practices (practices other than those which control the generation or source(s) of pollutant(s) used to divert, infiltrate, reuse, or otherwise manage storm water runoff in a manner that reduces pollutants in storm water discharges from the site. The plan shall provide that measures that the permittee determines to be reasonable and appropriate shall be implemented and maintained. The potential of various sources at the facility to contribute pollutants to storm water discharges associated with industrial activities under the SIC codes identified under paragraph XI.AD.1. of this section shall be considered when determining reasonable and appropriate measures. Appropriate measures may include: vegetative swales and practices, reuse of collected storm water (such as for a process or as an irrigation source), inlet controls (such as oil/water separators), snow management activities, infiltration devices, and wet detention/retention devices.

**Comprehensive Site Compliance Evaluation.** Qualified personnel shall conduct site compliance evaluations at least once a year. Such evaluations shall include:

Visual inspection of areas contributing to a storm water discharge for evidence of, or the potential for, pollutants entering the drainage system. Inspection shall address areas associated with the storage of

Tennessee Storm Water Multi-Sector  
General Permit for Industrial Activities (TMSP)  
**Sector AE**

raw metals, storage of spent solvents and chemicals, drainage from roof, unloading and loading areas, equipment storage areas, recycling areas, and retention ponds (sludge). Measures to reduce pollutant loadings shall be evaluated to determine whether they are adequate and properly implemented in accordance with the terms of the permit or whether additional control measures are needed. Structural storm water management measures, such as detention basins and channels, gutters or drains to direct discharge flow, oil/water separators in storm drains, containment structures, concrete pads, sediment and erosion control measures, and other structural pollution prevention measures identified in the plan shall be observed to ensure that they are operating correctly. A visual inspection of equipment needed to implement the plan, such as spill response equipment and containment drums, shall be made to determine if the equipment is functioning properly and that drums are not in a corrosive or deteriorating state.

Based on the results of the evaluation, the description of potential pollutant sources identified in the plan in accordance with paragraph XI.AD.3.a.(2) of this section (Description of Potential Pollutant Sources) and pollution prevention measures and controls identified in the plan in accordance with paragraph XI.AD.3.a.(3) of this section (Measures and Controls) shall be revised as appropriate within 2 weeks of such evaluation and shall provide for implementation of any changes to the plan in a timely manner, but in no case more than 12 weeks after the evaluation.

A report summarizing the scope of the evaluation, personnel making the evaluation, the date(s) of the evaluation, major observations relating to the implementation of the storm water pollution prevention plan, and actions taken in accordance with paragraph XI.AD.3.a.(4)(b) (above) of the permit shall be made and retained as part of the storm water pollution prevention plan for at least 3 years from the date of the inspection. The report shall identify any incidents of noncompliance. Where a report does not identify any incidents of noncompliance, the report shall contain a certification that the facility is in compliance with the storm water pollution prevention plan and this permit. The report shall be signed in accordance with Part VII.G. (Signatory Requirements) of this permit.

Where compliance evaluation schedules overlap with inspections required under 3.a.(3)(d), the compliance evaluation may be conducted in place of one such inspection.

#### 4. Numeric Effluent Limitations

There are no additional numeric effluent limitations beyond those described in Part V.B. of this permit.

#### 5. Monitoring and Reporting Requirements

a) Quarterly Visual Examination of Storm Water Quality. Facilities shall perform and document a visual examination of a storm water discharge associated with industrial activity from each outfall, except discharges exempted below. The examination must be made at least once in each designated period [described in paragraph (1) below] during daylight hours unless there is insufficient rainfall or snow melt to produce a runoff event.

(1) Examinations shall be conducted in each of the following periods for the purposes of visually inspecting storm water quality associated with storm water runoff or snowmelt: January through March; April through June; July through September; and October through December.

(2) Examinations shall be made of samples collected within the first 30 minutes (or as soon thereafter as practical, but not to exceed 1 hour) of when the runoff or snowmelt begins discharging. The

examinations shall document observations of color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution. The examination must be conducted in a well lit area. No analytical tests are required to be performed on the samples. All such samples shall be collected from the discharge resulting from a storm event that is greater than 0.1 inches in magnitude and that occurs at least 72 hours from the previously measurable (greater than 0.1 inch rainfall) storm event. Where practicable, the same individual should carry out the collection and examination of discharges for the entire permit term.

(3) Visual examination reports must be maintained onsite in the pollution prevention plan or with other compliance records. The report shall include the examination date and time, examination personnel, the nature of the discharge (i.e., runoff or snow melt), visual quality of the storm water discharge (including observations of color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution), and probable sources of any observed storm water contamination.

(4) When a facility has two or more outfalls that, based on a consideration of industrial activity, significant materials, and management practices and activities within the area drained by the outfall, the permittee reasonably believes discharge substantially identical effluents, the permittee may collect a sample of effluent of one of such outfalls and report that the examination data also applies to the substantially identical outfall(s) provided that the permittee includes in the storm water pollution prevention plan a description of the location of the outfalls and explains in detail why the outfalls are expected to discharge substantially identical effluents. In addition, for each outfall that the permittee believes is representative, an estimate of the size of the drainage area (in square feet) and an estimate of the runoff coefficient of the drainage area [e.g., low (under 40 percent), medium (40 to 65 percent), or high (above 65 percent)] shall be provided in the plan.

(5) When a discharger is unable to collect samples over the course of the visual examination period as a result of adverse climatic conditions, the discharger must document the reason for not performing the visual examination and retain this documentation onsite with the records of the visual examinations. Adverse weather conditions which may prohibit the collection of samples include weather conditions that create dangerous conditions for personnel (such as local flooding, high winds, hurricane, tornadoes, electrical storms, etc.) or otherwise make the collection of a sample impracticable (drought, extended frozen conditions, etc.).

(6) When a discharger is unable to conduct visual storm water examinations at an inactive and unstaffed site, the operator of the facility may exercise a waiver of the monitoring requirement as long as the facility remains inactive and unstaffed. The facility must maintain a certification with the pollution prevention plan stating that the site is inactive and unstaffed so that performing visual examinations during a qualifying event is not feasible